

Danfoss Industrial Refrigeration A/S

Stormosevej 10 – PO Box 60
DK-8361 Hasselager, Denmark
Telephone: +45 87 38 96 00
Fax: +45 86 28 08 01

AS Reg. No: 166 373
Bankers: Danske Bank
Acc. No.: 3627517599

DECLARATION OF CONFORMITY TEST CERTIFICATE

EN 45014

Our C/O No.	of the
-------------	--------

Your order	of the
------------	--------

The quality of Danfoss products is constantly monitored and controlled through Danfoss' quality assurance system, which is certified in accordance with ISO 9001.

A description of the quality assurance system, and the scope of registration can be obtained directly from Danfoss.

Product type Pilot valve CVP, CVPP (HP)	Certificate No 027B14C2
--	----------------------------

We hereby confirm that CVP and CVPP are made and delivered according to DIN 3158

Material:

Cover	: GGG 40.3	W.nr. 0.7043	DIN 1693
Flange	: St. 37-2,	W.nr. 1.0038	EN DIN 10025
Bottom part:	Free cutting steel	W.nr. 1.0718	DIN 1651
Bolts	: St 8.8		DIN ISO 898

Permissible working range:

Max. Working pressure : PB 28 bar
Media temperature range: -60 → +120°C

Safety:

Test pressure : p' 42 bar
Burst pressure : > 140 bar

Date 01-01-2001	Prepared by Mogens Søgaard	Date 01-01-2001	Approved by N. P. Vestergaard / R&D Mgr.
--------------------	-------------------------------	--------------------	---