

Declaration of Conformity



Number:	EU DoC P78c.docx
Manufacturer:	Johnson Controls Inc.
Address, City:	507 E. Michigan St. Milwaukee, WI 53202
Country:	USA
Phone number:	1-414-524-4500

Certify and declare under our sole responsibility that the following:

Description:	Adjustable pressure switch, these pressure controls are designed for use in a variety of applications involving refrigeration high or low pressure. They may also be used for other high or low pressure applications such as air, water etc.
Product name:	P78 Dual Pressure Switch
Brand:	Johnson Controls / PENN
Identification:	

LVD 2014 / 35 / EU					
EMC 2014 / 30 / EU					
P78ALA-9351	P78ALA-9451	P78MCA-9300	P78MCA-9320	P78MCA-9400	P78MCA-9700
P78LCA-9300	P78LCA-9301	P78LCA-9320	P78LCA-9400	P78LCA-9500	P78LCA-9700
P78PGA-9300	P78PGA-9320	P78PGA-9400	P78PGA-9700	1089921410	

LVD 2006 / 95 / EC					
EMC 2014 / 30 / EU					
PED 2014 / 68 / EU					
PED Safety Accessory, Category IV, PS = 33 Barg, V = 1 cm ³ , Group 2 Fluids, TS = -20°C T 55°C					
P78LCW-9300	P78LCW-9302	P78LCW-9303	P78LCW-9320	P78LCW-9321	P78LCW-9800
P78LCW-9801	P78LCW-9802	P78MCB-9300	P78MCB-9320	P78MCB-9800	P78MCB-9802
P78MCB-9803	P78MCS-9300	P78PGB-9300	P78PGB-9800	P78PLM-9350	P78PLM-9850
P79PLM-9856					
PED Safety Accessory, Category IV, PS = 48 Barg, V = 1 cm ³ , Group 2 Fluids, TS = -20°C T 55°C					
P78LCW-9355	P78LCW-9356	P78MCB-9355	P78PLM-9355		

The following standards have been used in the assessment:

LVD	2014 / 35 / EU	EN 60730-1:2000 +A12:2003 +A13:2004 +A1:2004 +A14:2005 +A16:2007 +A2:2008
LVD	2014 / 35 / EU	EN 60730-2-6:2008
LVD	2014 / 35 / EU	EN 60529:1989/A2:2013
PED	2014 / 68 / EU	EN 12263:1999
EMC	2014 / 30 / EU	EN 55014-1:2006, A1:2009; A2:2011

and complies with the requirements and provisions of the regulations.



The following 3rd party body has issued the certificates:

Identification of body:	Reference number Letter of Opinion:	Certificate type	Name and address of 3 rd party body:
0038	0038 / PED / HOU / NAO 020216 / 2	PED, Module B	Lloyd's Register 71 Fenchurch Street London EC3M 4BS, UK
2561	HSB UK – 14 – 09 - 027	PED, Module D	HSB Global Standards Hartford Steam Boiler UK Limited Crosby Court 28George Street Birmingham, B3 1QG, England

The Technical documentation can by the Surveillance Authorities be requested at the following address:

Company:	Johnson Controls Inc.
Address, City:	Westendhof 3, 45143 Essen
Country:	Germany

Name and position of persons authorised by the manufacturer:

Apr. 12, 2016 Date	 Roy M Rader, Director Engineering	04-11-2016 Date	 Fernando Gonzalez Saucedo Quality Assurance Leader Juarez Facility
--------------------------	--	--------------------	--